



A-005



Pass

Test Time : 2/22/2024 1:59:02 PM
Project : fo1
Profile : Validation
Operator : Default
Main Adapter : AD-NSA, S/N: 61154

Limit : IEEE 802.3
Serial Number : Main: 4200-0044
Device Software : 4.2.308
Calibration Date : 5/4/2021
Remote Adapter : AD-NSA, S/N: N/A



Approximate Length : 53.00 m

SNR

Network Speed	Result	Limit	Pair 12 (dB)	Pair 36 (dB)	Pair 45 (dB)	Pair 78 (dB)
10G	Pass	0.0	4.6	3.3	4.4	4.8
5G	Pass	0.0	9.3	7.0	7.8	9.4
2.5G	Pass	0.0	12.5	10.7	12.7	12.5
1G	Pass					
100M	Pass					

POE

PSE Type	4
PD Class	8
Cable Pairing	12-36 & 45-78
Allocated Power	71.30 W
Voltage	52.73 V
Current	1.323 A
Real Power	69.74 W

PoE load measurement is compliant to Class 1,2,3,4,5,6,7